

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Lab. Chemt (2025-26) 56

Dated: 30-4-2025

It is certified that an inspection team headed by JUNIOR CHEMIST - PHED

(Name of Officers with designation) from PAWAN KUMAR SHARMA PHED - KARALI

inspected the SHRI KAILADEVI MANDIR SR SEC SCHOOL
BARHAMA ROAD KAILADEVI Letter NO. 2713-04/28.4.25
(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2025-26/56 28.4.25 dated 28.4.2025

of PHED LAB KARALI (PHED Lab) certified that

the SHRI KAILADEVI MANDIR SR SEC SCHOOL KAILADEVI (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 30.4.2026

Signature with Seal: Pawan Kumar Sharma

Name

Designation

Name & Address of the Office / Department : PHED LAB

To SHRI KAILADEVI MANDIR -
SR SEC SCHOOL BARHAMA ROAD -
KAILADEVI DIST. KARALI
(Name & Address of the Institution) (RAS)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

कार्यालय ग्राम पंचायत कैलादेवी, जिला करौली (राज0)

क्रमांक :- /ग्र.प./2025-26/ 132-33


दिनांक :- 19/09/2025

विद्यालय स्वच्छता का अनापत्ति प्रमाण-पत्र

प्रमाणित किया जाता है कि श्री कैलादेवी मंदिर उच्च माध्यमिक विद्यालय कैलादेवी, जिला करौली (राज0) ने निर्धारित स्वच्छता मानकों का पालन किया है। हमारे निरीक्षण दल ने दिनांक 19/09/2025 को उपरोक्त Premises का निरीक्षण किया और पाया कि :-

- स्वच्छता की स्थिति संतोषजनक है।
- पानी की आपूर्ति स्वच्छ है।
- कचरा निपटान की व्यवस्था उचित है।
- अन्य सभी आवश्यक स्वच्छता संबंधी नियम-कानूनों का पालन किया गया है।
- विद्यालय में छात्र-छात्राओं के लिए अलग-अलग पर्याप्त संख्या में शौचालय एवं मूत्रालय हैं जिनकी दैनिक सफाई होती है।

यह प्रमाण-पत्र आज दिनांक 19/09/25 को जारी किया गया।



प्रवीण कुमार शर्मा
ग्राम विकास अधिकारी
ग्राम पंचायत कैलादेवी
जिला करौली (राज0)

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, KARALI

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Jr. Chem./2025-26/ 56

Date-30.04.2025

To. 
 PRINCIPAL
 SHRI KAILADEVI MANDIR SRSECSCHOOL
 BARGAMA ROAD KAILADEVI
 ur Ref. Letter no-2713 Date-28.04.25

Particulars	Source		TW
	Location		SHRI KAILADEVI MANDIR SRSECSCHOOL
Block			KARALI
Village/Town			KAILADEVI
Date of Collection			28.04.25
Date of receipt			28.04.25
Date of Examination			28.04.25
Sample No			P3
Permission value as per			
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	
1 pH	6.5-8.5	6.5-8.5	8.0
2. Turbidity (NTU)	1	5	0.2
3. Colour (Hazen Units)	5	15	
4. Odour	Un Objectionable		
5. Total Alkalinity (as CaCo ₃) mg/l	200	600	180
6. Total Hardness (as CaCo ₃) mg/l	200	600	330
7 Chloride (as Cl-) mg/l	250	1000	170
8. Sulphate	200	400	
9. Fluoride mg/l	1	1.5	0.49
10 Nitrate	45	No relaxation	22
11 Iron	0.3	No relaxation	
12 Residual Chlorine	0.2	2	
13. Total dissolved solids	500.0	2000	880

NOTE- SAMPLE NOT COLLECTED BY LAB

प्रयोगशाला
 कमिष्ठ रसायनज्ञ
 PHE D. Laboratory Karali
 प्रयोगशाला कराली